

Licence Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 12/12/18

Obtained: 14/1/19

Published: 16/1/19

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	12	200	µg/L	No
		Electrical Conductivity	1770	1780	µS/cm	No
		Nickel	43	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	11	30	mg/L	No
		Turbidity	23.3	150	NTU	No
		Zinc	38	300	µg/L	No