

Licence Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 12/4/19

Obtained: 24/4/19

Published: 3/5/19

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	25	200	µg/L	No
		Electrical Conductivity	1990	1780	µS/cm	No
		Nickel	63	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	7.3	150	NTU	No
		Zinc	58	300	µg/L	No