**Licence Holder**: Tahmoor Coal Pty Ltd **Site Address**: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573 **EPL Number**: 1389

Sampled: 7/05/2020 Obtained: 2/6/2020 Published: 2/6/2020

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Arsenic	30	200	μg/L	No
		Electrical Conductivity	2120	2600	μS/cm	No
		Nickel	62	200	μg/L	No
		Oil and Grease	<5	10	mg/L	No
		рН	8.3	6.5-9.0	units	No
		Total Suspended Solids - TSS	\$	30	mg/L	No
		Turbidity	10.3	150	NTU	No
		Zinc	40	300	μg/L	No