

**License Holder:** Tahmoor Coal Pty Ltd  
**Site Address:** Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573  
**EPL Number:** 1389

**Sampled:** 10/01/17

**Obtained:** 20/01/17

**Published:** 02/02/17

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	96	200	µg/L	No
		Electrical Conductivity	1950	2600	µS/cm	No
		Nickel	63	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.4	6.5-9.0	units	No
		Total Suspended Solids - TSS	7	30	mg/L	No
		Turbidity	1.3	150	NTU	No
		Zinc	183	300	µg/L	No