

License Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389

Sampled: 6/7/17
Obtained: 14/7/17
Published: 21/7/17

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	37	200	µg/L	No
		Electrical Conductivity	1940	2600	µS/cm	No
		Nickel	64	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.8	6.5-9.0	units	No
		Total Suspended Solids - TSS	8	30	mg/L	No
		Turbidity	4.2	150	NTU	No
		Zinc	40	300	µg/L	No