

License Holder: Tahmoor Coal Pty Ltd

Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573

EPL Number: 1389

Sampled: 10/10/17

Obtained: 17/10/17

Published: 20/10/17

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedence (yes/no)
1	Monthly	Arsenic	73	200	µg/L	No
		Electrical Conductivity	1420	2600	µS/cm	No
		Nickel	66	200	µg/L	No
		Oil and Grease	<5	10	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	18	30	mg/L	No
		Turbidity	7.2	150	NTU	No
		Zinc	101	300	µg/L	No