

Licence Holder: Tahmoor Coal Pty Ltd
 Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
 EPL Number: 1389



Sampled: 12/04/2023
 Obtained: 03/05/2023
 Published: 03/05/2023

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Aluminium	<10	110	µg/L	No
		Arsenic	38	200	µg/L	No
		Barium	2320	6440	µg/L	No
		Electrical Conductivity	1810	2600	µS/cm	No
		Copper	<1	5	µg/L	No
		Enterococci	13	1700	CFU/100ml	No
		Nickel	47	200	µg/L	No
		Nitrogen	2.6	8	mg/L	No
		pH	8.6	6.5-9.0	units	No
		Total Suspended Solids - TSS	6	30	mg/L	No
		Turbidity	6.0	150	NTU	No
		Zinc	48	300	µg/L	No