

Licence Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389



Sampled: 08/08/2024
Obtained: 18/08/2024
Published: 18/08/2024

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Aluminium	<10	110	µg/L	No
		Arsenic	27	200	µg/L	No
		Barium	3910	6440	µg/L	No
		Electrical Conductivity	1580	2600	µS/cm	No
		Copper	<1	5	µg/L	No
		Enterococci	16	1700	CFU/100ml	No
		Nickel	43	200	µg/L	No
		Nitrogen	2.7	8	mg/L	No
		pH	8.5	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	2.8	150	NTU	No
		Zinc	51	300	µg/L	No