

Licence Holder: Tahmoor Coal Pty Ltd
Site Address: Tahmoor Colliery Remembrance Drive, Tahmoor, NSW, 2573
EPL Number: 1389



Sampled: 10/10/2024
Obtained: 21/11/2024
Published: 21/11/2024

Sampling Point	Monitoring frequency required by licence	Pollutant	Measurement	Limit	Unit	Exceedance (yes/no)
1	Monthly	Aluminium	<10	110	µg/L	No
		Arsenic	<1	200	µg/L	No
		Barium	150	6440	µg/L	No
		Electrical Conductivity	108	2600	µS/cm	No
		Copper	<1	5	µg/L	No
		Enterococci	35	1700	CFU/100ml	No
		Nickel	<1	200	µg/L	No
		Nitrogen	0.3	8	mg/L	No
		pH	7.1	6.5-9.0	units	No
		Total Suspended Solids - TSS	<5	30	mg/L	No
		Turbidity	0.2	150	NTU	No
		Zinc	40	300	µg/L	No